BRIEF TECHNICAL SPECIFICATION FOR 10 WAY MICRO CONTROLLER BASED SEQUENTIAL TIMER CARD

1. ITEM	10 WAY Micro Controller Base Sequential Timer Card
2. MODEL	MpS1WD-9#1
3. APPLICATION	TO PROVIDE TIMED SEQ. ENERGISATION OF PILOT SOLENOID VALVE
4. DETAIL OF CONTROLLER (PCB)	
4.1 INPUT SUPPLY	110V AC or 220V AC *, 50 or 60 Hz.
4.2 INPUT FUSE (ENCLOSED TYPE)	1 Amp. 110, 220V AC, (GLASS 20mm)
4.3 ON TIME	20 TO 200 MILLISECONDS
4.4 OFF TIME	2 TO 60 SECONDS.
4.5 NUMBER OF SEQ. STEPS	1 TO 10 ADJ. through Flying Lead
4.6 TEMP. RANGE OPERATION	0 TO 55o C
4.7 CURRENT RATING PER SEQ.:	
a) MAXIMUM INRUSH CURRENT	10 Amps.
b) MAX. CONTINUOUS CURRENT	2 Amps. [1", 2 Nos. (Max. of Solenoid Valves per channel **)]
4.8 MAINS ISOLATION SWITCH	PROVIDED ON PCB
4.9 ON DEMAND CONTROL (PRESSURE SW. CONTACT)	PR. SW. TERMINALS (P1, P2) SEQUENCE CONTROLLER STOPS WHEN CONTACT AT PR.SW. OPENS. (PR. LED GLOWS, & CLOCK LED STEADY ON) SEQ. CONTINUES FROM POINT WHERE IT HAD STOPPED, WHEN CONTACT RE-CLOSES.
4.10 LED VISUAL INDICATIONS:	
a) POWER ON INDICATION	1 No. LED (5mm - RED COLOR)
b) OUTPUT ON INDICATION	10 Nos. LED (5mm - RED COLOR)
C) ON DEMAND MODE	1No. LED (5mm - RED COLOR)
d) MANUAL PULSING	1No. LED (5mm - RED COLOR)
5. MANUAL PULSING	FACILITY PROVIDED (P.B. SW.)
6. FEED BACK RELAY	POTENTIAL FREE CONTACT, 5A @230 V AC
7. PCB DETAILS:	SINGLE SIDE, GREEN MASKED, IDENT, WITH ANTI CORROSIVE LOCTITE SPRAY COATING.
a) P.C.B. DIMENSIONS	215 (L) x 145mm (W)
b) P.C.B. MOUNTING SIZE	205(L) x 135(W) mm (MOUNTING HOLES 4 Nos. 4mm)
c) UL	APPROVAL 94V-0SL1
8. ENCLOSURE DETAILS **(Optional Extra)**	TYPE- IP-55, SIEMENS GREY POWDER COATED (MOC: M.S. CRCA 1.6 Thk.)
a) ENCLOSURE SIZE	300(W) x 300(H) x 135(D)mm or 300X400X205(D)
b) ENCLOSURE OVER ALL SIZE	380(W) x 365(H) x 150(D)mm
c) MOUNTING DIMENSIONS	330(W) x 220(H)mm, WALL MOUNTED. OR PLOYCARBONATE TRANPARENT LID 300 x250 x135
9. TEST CERTIFICATE	ONE COPY WITH EACH CONTROLLER
10. MAKE	X'CALIBUR AUTOMATION, PUNE-30

Note : * Supplied as 110V AC only or 220V AC only.
** Only Solenoid Makes of X'CALIBUR, ASCO, GOYEN CONTROLS, MECAIR AND AVCON must be used which are pulse duty Bag Filter application Solenoids.

PDF created with pdfFactory Pro trial version www.pdffactory.com

PDF created with pdfFactory Pro trial version www.pdffactory.com